

MOTOR DATA SHEET

Motor type: **2Sg315S4-(2D,3D)**

Series: Gas and Dust - category 2D, 3D, 3G



06-06-2025

| | ELECTRICAL PARAMETERS | | | | | | | | | | | | | | | | |
|-----|-----------------------|----|-----|-----|------|-----|------|-----|------|------|------|--------|-------------|-------|-------|---------------|---------|
| U | CONN. | f | F | 9 | Duty | 1 | n | Т | TL/T | TB/T | IL/I | Effici | ency at loa | d [%] | Power | r factor at l | oad [-] |
| V | - | Hz | kW | HP | - | Α | rpm | Nm | - | - | - | 2/4 | 3/4 | 4/4 | 2/4 | 3/4 | 4/4 |
| 400 | Δ | 50 | 110 | 150 | S1 | 183 | 1480 | 710 | 2.3 | 2.2 | 6.9 | 94.1 | 94.4 | 94.2 | 0.86 | 0.90 | 0.92 |

| GENERAL DATA | | | | | | |
|----------------------------|-----------------------|--------------------------------------|---------------|--|--|--|
| Efficiency class | - | Sound pressure level [dB] | 76 | | | |
| Frame size | 315 | Sound power level [dB] | 86 | | | |
| Number of poles | 4 | Terminal box position | on right side | | | |
| Starting method | DOL or Y/Δ | Possibility of terminal box rotation | yes | | | |
| Insulation class | F | Bearing on D-side | 6318C3 | | | |
| Frequency converter supply | on demand | Bearing on ND-side | 6318C3 | | | |
| Mounting arrangement | IMB3/B5/B35 | Bearings regreasing | yes | | | |
| Cooling method | IC411 | Housing - material | cast iron | | | |
| Weight (IMB3) [kg] | 785 | Feet - material | cast iron | | | |
| Moment of inertia [kgm2] | 1.67 | Bearing shields - material | cast iron | | | |
| Direction of rotation | CW/CCW | Painting | RAL5010 | | | |
| Degree of protection | IP66 (2D) / IP56 (3D) | Climatic execution | N | | | |

| | ENVIRONMENTAL CONDITIONS | | | | | | | |
|--------------------------|--------------------------|------------------------------|------------|--|--|--|--|--|
| Ambient temperature [°C] | from -20 up to +40 | Altitude above sea level [m] | up to 1000 | | | | | |
| Relative humidity [%] | up to 95 | | | | | | | |

| ACCESSORY | | | | | | |
|--------------------------------|---------|---------------------------------|-----------------------|--|--|--|
| Number of terminals or cables | 6 | Temperature sensors in bearings | 2 x PTC (1pc/bearing) | | | |
| Cable glands/inlets | 2 + 1 | Winding heaters | on demand | | | |
| Temperature sensors in winding | 3 x PTC | Optional accessories | on demand | | | |

| STANDARDS | | | | | |
|--|--|--|--|--|--|
| EN 60034-1, EN 60079-0, EN 60079-15, EN 60079-31 | | | | | |

| CERTIFICATES |
|--------------|
| ATEX |

| | NAL INFO | | |
|------------|--|--|--|
| Ex marking | II 2D,3D Ex t IIIC,IIIB T120°C Db / II 3G ExnA II | | |
| | T4 Gc | | |

